

Certificate No: ET-0346-22

Name and address of the sponsor: Haapsalu Uksetehase AS, Masti 8, Uuemõisa 90401, Ridala vald, Lääne maakond, ESTONIA

Name and address of the producer: Haapsalu Uksetehase AS, Masti 8, Uuemõisa 90401, Ridala vald, Lääne maakond, ESTONIA

Product: Wood-glass partitions and partitions EI30

Date: 22.08.2022

1. Essential characteristics and performance

Classification according to EN 13501-2:2016: EI30.

Essential characteristics	Performance								
	Resistance to fire	-	E20	E30	-	E60	E90	E120	-
EI15		E20	EI30	EI45	EI60	EI90	EI120	EI180	EI240
-		-	EI-M 30	-	EI-M 60	EI-M 90	EI-M 120	EI-M 180	EI-M 240
-		EW20	EW30	-	EW60	EW90	EW120	-	-

2. Product specification and field of application

Dimensions	max W, mm	max H, mm
Wall construction	– ⁽¹⁾	3552
Wooden modules	1122	2748
	2430	804
Glazed modules ⁽²⁾	1122	3552

Glazing	max W, mm	max H, mm	max A, m ²
Pyrostop 30-10, thickness 15 mm	1050	2712	2,39

Glazed modules may be fitted with or without horizontal transoms.

3. General field of application

Change in the angle of installation of up to 10° from the vertical is permitted, provided the height of wall construction is ≤ 2960 mm.

Modular partition wall may be mounted only in rigid supporting construction.

¹ Width of the wall construction depends on placement, dimensions, and number of modules

² Maximum allowed dimensions of glazing should be considered.